



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

Date: February 8th, 2018

System No. 3301529

Ramona Water System
PO Box 390626
Anza CA, 92539

Enclosed is Citation No. 05_63_18C_005 issued to Ramona Water Company a public water system. Please note that there are certain deadlines associated with this Citation.

Any person who is aggrieved by a Citation issued by the Riverside County LPA may file a petition with the State Water Resources Control Board (State Water Board) for reconsideration of the Citation. Petitions must be received by the State Water Board within 30 calendar days of the issuance of the Citation. The date of issuance is the date when the Riverside County LPA mails or serves a copy of the Citation, whichever occurs first. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day. Petitions must be received by 5:00 p.m. Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

If you have any questions regarding this matter, please contact this Department at 951-955-8980

Sincerely,

Daisy E. Ciudad Real, M.P.H., R.E.H.S

Certified Mail: 70173040000085608496



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

**CITATION FOR NONCOMPLIANCE – WATER SYSTEM NO. 3301529
NO. 05_63_18C_005**

Date: February 8th, 2018

Re: Ramona Water System
System No. 3301529

To: Ramona Water Company
PO Box 390626
Anza CA, 92539

Section 116650, Article 9, Chapter 4, Part 12, Division 104 of the California Health and Safety Code (H&S Code), authorizes the issuance of a citation for failure to comply with the requirements of the California Safe Drinking Water Act, or any regulation, standard, permit order issued there under.

VIOLATION

The Department of Environmental Health (Department), hereby issues a citation to Ramona Water Company for the following violations:

Title 22 of the California Code of Regulations (CCR), Section 64432 specifically, Ramona Water Company failed to sample Well # 2 and #5 for Inorganic Chemicals between the period of 2015-2017. All public water systems using groundwater shall monitor for Inorganic Chemicals very three years.

Title 22 of the California Code of Regulations (CCR), Section 64449 specifically, Ramona Water company failed to sample well #2 and #5 for Secondary Drinking Water Standards between the period of 2015-2017. All public water systems using groundwater shall monitor for Secondary Drinking Water Standards every three years.

Title 22 of the California Code of Regulations (CCR), Section 64444 specifically, Ramona Water Company failed to sample the Patterson well for Volatile Organic Chemicals (VOCs). This water system must sample all active well for VOCs every six years.

Title 22 of the California Code of Regulations (CCR), Section 64442 specifically, Ramona Water company failed to sample well #2, # 4, #5 and the Patterson well for Gross Alpha Particles between the period of 2015-2017. This water system must sample all active wells every three years, for Gross Alpha Particles and must follow the radiological rule.

CHRONOLOGY OF EVENTS

The water system sources currently consists of four active drilled wells: Well #2 (Red Shank) has a 6 inch diameter casing to 195 foot depth and is serviced by a 2 hp submersible pump. Well #3 (Burnt Valley Well) has a 6 5/8" diameter casing to 270 foot depth. Well #4 (Reynolds Way) has a 6" diameter casing to 230 foot depth and is serviced by a 2 hp submersible pump. Well #5 (Everett Road) is 400 feet deep with 55 feet of 6 5/8" casing and is serviced by a 1 hp submersible pump. Well #7 (Anzanita) is 400 feet deep with 130 feet of 6 5/8" casing and is serviced by a 2 hp submersible pump.

The Patterson Well (3301529-013) is located on an adjacent piece of property and is currently being used on an interim basis. It is 600' deep with an 8" casing with a 5 hp submersible pump.

RECENT HISTORY

The water system was last inspected on 10/28/2015. The system was provided a sampling schedule that showed the compliance date for sampling of each well.

DIRECTIVES

Submit all results for missing sampling to this Department once you have been notified by the laboratory. Ensure that all samples are EDT by the lab.

Failure to comply with sampling schedule for wells could result in citations with penalty.

This is considered a monitoring and reporting (M&R) violation and requires public notification utilizing the Tier 3 notification method, which is notification to the consumers. All consumers served by this water system must be notified of this violation, as required in Section 64463.7, by listing the violation on the 2017 CCR. Submit a Proof of Notification to this Department once the notice has been delivered to your water consumers.

FURTHER ENFORCEMENT ACTION

Failure to comply with this notice and/or failure to comply with Title 22 of the California Code of Regulations may result in an administrative office hearing and assessment of administrative penalties. This Department does not waive any further enforcement action by issuance of this citation.

If you have any questions, please contact this Department at (951) 955-8980



Daisy Ciudad Real, M.P.H., R.E.H.S.
Environmental Health Specialist

Certified Mail: 7017 3040 0000 8560 8496